



611 Erie St. South, P.O. Box 907, Massillon, OH 44648-0907
330-833-8555 ■ 800-589-8555

Dear _____

Customer # _____

Address _____

_____ Phone _____

Safety is our top priority at Campbell Oil Company. I have circled the following unsafe item(s) that require(s) your attention

- 1. Tank is in an unsafe location or needs a safe means of access by deliveryman.
- 2. Tank needs a gauge for safety through awareness.
- 3. Inside tank fill and vent lines need to be plumbed to the outside to prevent unnecessary annoying fumes and fill hose-ruptures from occurring inside
- 4. Needs a larger vent pipe of at least 1 1/4" diameter to prevent pressure from building up in tank and causing a rupture
- 5. Vent pipe obstruction needs removed.
- 6. Vent pipe needs a vent alarm (tank whistle) to help prevent tank overflows.
- 7. Plastic fill pipes and vent pipes required to be replaced with schedule 40 black pipe to meet code NFPA 31. (Pipe diameters must be at least 2" for fill, 1 1/4" for vent)
- 8. Please keep your fill pipe accessible by trimming back bushes and trees.
- 9. Please keep your driveway clear of branches and/or ice so that our driver can pull in safely.

Other _____

_____ Please fix these item(s) at your earliest convenience: Item(s) #: _____

_____ ITEM(S) MUST BE FIXED PRIOR TO ANOTHER DELIVERY: Item(s) #: _____

_____ Please contact our office to schedule a convenient time for a visit by one of our service personnel to discuss correcting the unsafe situation

We will call you in the next couple of days to answer any questions that you may have.

Thank you for maintaining a safe system and trusting Campbell Oil Company with your family's home comfort!

Sincerely,

_____, Delivery Driver

Notes: S A F E T Y I S T